

October 17, 2025

Town Board: Kurt Sawyer, Gary Goble, Janell Barney

Staff: Carly Burrows

Public:

1. Meeting Called to Order

Councilor Sawyer called the meeting to order and began the meeting at 10:00am.

3. Water system review for approval

- Focus: Emergency repairs and resiliency upgrades for the town water system.
- Issues identified: Failed tank sensor at Well 4; no battery backup for the tank level system; aging UPS in the main building; consideration to add UPS units at Well 4 and Well 5.
- Proposed solution: Install a battery level indicator for the tank and new UPS units. Electrician (KMEC Electric, working under Tyler) to handle the work; parts roughly \$300 per UPS, labor not yet estimated.
- Motion and decision: Motion approved to authorize up to \$2,500 to cover the repairs and equipment. Passed unanimously; meeting adjourned shortly after .

Councilor Sawyer motion to approve \$2,500 system, Councilor Barney 2nd the motion, the vote was unanimous.

4. Adjournment

Councilor Sawyer motion to adjourn at 10:15am, Councilor Goble 2nd the motion, the vote was unanimous.

HATCH TOWN BOARD MEETING